


INSTALLATION OF SW-JV60-G1 SWIVEL FITTING

TOP VIEW
JVx-60xG




SENSOR HOLE WITH
TAPERED BOTTOM

SENSOR HOLE WITH
FLAT BOTTOM


ORIENTATE AS SHOWN

INSTALL SENSOR
IN FLAT-BOTTOMED
SENSOR HOLE. MAKE
SURE IT IS COMPLETELY
SEATED.


TOP VIEW
JVx-60xG



TIGHTEN CLAMP
SCREW UNTIL SENSOR UNIT
IS SECURE.



SW-JV60-G1
CLAMP FITTING

REVISION	DESCRIPTION	DATE	BY	AW-LAKE COMPANY USE ONLY	TOLERANCES UNLESS NOTED ENGLISH	PROJECT NAME: INSTALLATION GUIDE SW-JV60-G1	PART DESCRIPTION: SW-JV60-G1	
C	REVISED COMPANY LOGO	12/7/11	JP	THIS PRINT, INCLUDING THE INFORMATION CONTAINED IN IT IS THE PROPERTY OF AW-LAKE COMPANY. IT IS CONSIDERED PROPRIETARY IN NATURE AND MAY NOT BE USED OR DISCLOSED OUTSIDE OF AW-LAKE COMPANY, EXCEPT UNDER PRIOR WRITTEN AGREEMENT. ANY MODIFICATIONS MADE TO OR COMMENTS WRITTEN ON THIS DRAWING BY UNAUTHORIZED PERSONNEL WILL VOID THIS DRAWING. ALL DIMENSIONS SHOWN ARE SUBJECT TO CHANGE WITHOUT NOTICE.	. XXXX +/- .001	MATERIAL: NA	REV: C	
B	Added Screws To Drawing	08/31/07	SH		. XXX +/- .005	FINISH: NA	DRAWING NUMBER: SW-JV60-G1	
					. XX +/- .01	HARDENING: NA	PART NUMBER: SW-JV60-G1	
					FRAC. +/- 1/64	ANG. +/- 1 DEG	DATE: 08/31/07	
					SURFACE FINISH: 64 MAX	DRAWN BY: S. HONSBERGER		 AW-LAKE COMPANY A TASI GROUP COMPANY 8809 INDUSTRIAL DR. FRANKSVILLE, WI 53126 TEL. # (262) 884-9800 FAX. # (262) 884-9810
						PAGE: 1 OF 1		